

**ORP Horizontal Cabling Project, FY24**  
**RFQ 0979-24-IT01 (Amended)**  
**Q&A**

Q: What is a Walker duct?

A: It's a cable tray from the IDF going to a floor channel covered with carpet squares, cellular with knockouts adjacent to wiring boxes.

Q: Will cut-sheets providing the length and jack color for each wiring pull be provided?

A: Yes.

Q: Since the jacks and plates need to be consistent, will you provide the brand and part numbers we will need?

A: Yes, here are the part numbers:

Wall plates

1-Port - 43080-1S1

2-Port - 43080-1S2

3-Port - 43080-1S3

4-Port - 43080-1S4

6-Port - 43080-1S6

Jacks

Black - 6110G-RE6

Red - 6110G-RR6

Yellow - 6110G-RY6

Q: Are there any "66" blocks in these IDFs?

A: No, those are located in the demarc.

Q: Are we to dispose of all old patch panels and CAT3 wire?

A: Yes.

Q: Do we have any responsibility for patch cables or cable management?

A: No.

Q: Will the ordering of the cables in the patch panels remain the same as it is now?

A: No, the cable layout is currently pretty scattered. Cables will need to be reorganized and regrouped. The yellow jacks for access points should be grouped together in the first row of Probation's ports. Some things that do stay the same are the patch panels with white CAT6 cabling at the top of the racks in 335 and 346.1, and the fiber panels—don't touch those.

Q: Will we be required to mount any equipment?

A: No. The job is strictly wiring.

Q: Will new runs be needed for wireless Access Points?

A: No, we will use existing runs for those.

August 16, 2024

Page | 1

Q: May we see the blueprints?

A: The winning contractor will be provided access to the blueprints.

Q: Are there furniture sliders to help with the moving process in offices?

A: Yes, the District Court office has furniture sliders you may use.

Q: Will contractors need to badges for access to the building?

A: Yes.